

Brooke T. Paup, *Chairwoman*
Catarina R. Gonzales, *Commissioner*
Tonya R. Miller, *Commissioner*
Kelly Keel, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

May 28, 2026

MR SIMON ROSS
CHIEF COMMERCIAL OFFICER
IP MEITNER GAS LLC
140 NEW MONTGOMERY ST FL 11
SAN FRANCISCO CA 94105-3705

Re: Electric Generating Units Air Quality Standard Permit
(Effective 5/16/2007)
Standard Permit Registration Number: 184049
Standard Permit Expiration Date: May 28, 2036
Ip Meitner Gas Llc
Meitner Energy Center
Pampa, Gray County
Regulated Entity Number: RN112441241
Customer Reference Number: CN606512325

Dear Mr. Ross:

Ip Meitner Gas, LLC submitted an application on May 13, 2026 to register construction related to Electric Generating Units to be located at intersection of county road b and county road 21 northeast of pampa, Pampa, Gray County. We understand that this registration is for emissions associated with the installation of one hundred and twenty-six (126) engines.

The Texas Commission on Environmental Quality (TCEQ) has determined that your proposed emissions are authorized by this standard permit pursuant to Title 30 Texas Administrative Code § 116.602 and Texas Health and Safety Code § 382.05195, if constructed and operated as described in your registration. Authorized emissions are listed on the attached table.

You are also reminded that these facilities must comply with all rules and regulations of the TCEQ and of the U.S. Environmental Protection Agency at all times.


Permittees must report the operational status for each relevant standard permit registration by December 31st of each year electronically through the State of Texas Environmental Electronic Reporting System (STEERS). More information is available at www.tceq.texas.gov/permitting/air/annual-reporting-requirements-airpermits.

If you need further information or have any questions, please contact Ms. Dara Winsted at (512) 239-1544 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

Mr. Simon Ross
Page 2
May 28, 2026

Re: Standard Permit Registration Number 184049

Sincerely,

A handwritten signature in black ink that reads "Michael Partee". The signature is written in a cursive style with a large, stylized "M" and "P".

Michael Partee, Manager
Rule Registrations Section
Air Permits Division
Texas Commission on Environmental Quality

cc: Air Section Manager, Region 1 - Amarillo

Project Number: 409390

Standard Permit Maximum Emission Rates Table
Permit Number 184049

The facilities and emissions included in this table have been represented and reviewed as the maximum emissions authorized by this standard permit registration.

Emission Point No.	Source Name	Pollutant	Authorized Emissions	
			lbs/hr	tpy
ENG 1 – ENG-126*	Single Cat G3250 Engine Hourly Emissions Routine and MSS	VOC	0.30	--
		NOx	1.52	--
		CO	3.68	--
		PM	0.23	--
		PM ₁₀ / PM _{2.5}	<0.01	--
		SO ₂	0.01	--
		NH ₃	0.39	--
ENG 1 – ENG-126 CAP	Cat G3250 Engines Routine and MSS Annual Cap	VOC	--	140.79
		NOx	--	144.43
		CO	--	165.10
		PM	--	108.73
		PM ₁₀ / PM _{2.5}	--	0.85
		SO ₂	--	6.45
		NH ₃	--	183.02
FUG-1	Fugitives		0.26	1.13

*Emissions are per engine.

VOC - volatile organic compounds
 NO_x - total oxides of nitrogen
 CO - carbon monoxide
 PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
 PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5} as represented
 PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter
 SO₂ - sulfur dioxide

Note: Fugitive emission rates are estimates and are enforceable through compliance with the standard permit representations.

Date: May 28, 2026